

IAPMO RESEARCH AND TESTING, INC.

5001 East Philadelphia Street, Ontario, California 91761-2816 – USA • 909-472-4100 • 909-472-4244 • www.iapmort.org



CERTIFICATE OF LISTING

IAPMO Research and Testing, Inc. is a product certification body which tests and inspects samples taken from the supplier's stock or from the market or a combination of both to verify compliance to the requirements of applicable codes and standards. This activity is coupled with periodic surveillance of the supplier's factory and warehouses as well as the assessment of the supplier's Quality Assurance System. This listing is subject to the conditions set forth in the characteristics below and is not to be construed as any recommendation, assurance or guarantee by IAPMO Research and Testing, Inc. of the product acceptance by Authorities Having Jurisdiction.

The most updated information on this Certificate of Listing is available online at pld.iapmo.org

Effective Date: March 2017 -Rev. 5/11/2017- Void After: March 2018

Product: Gas Piping Corrugated Stainless Steel Tubing System File No. 7660

Issued To: Dong A Flexible Metal Tubes Co
264, Song Ju-ro, Yangji-myeon
Cheoin-gu
Yongin-si,, GYUNG G:-DO 449822
South Korea

Identification: Each component of piping system shall bear permanent markings which include the manufacturer's name, trademark or symbol, part number, symbol of the organization making the test for compliance with ANSI LC 1/CSA 6.26. The tubing shall also bear a permanent marking of the rated pressure, the equivalent hydraulic diameter (EHD) and the words "FUEL GAS". These markings shall appear on tubing at not less than 24-inch interval. In addition, each component supplied by the manufacturer shall bear a separate date code marking in accordance with ANSI LC 1/CSA 6.26, and shall also bear the cUPC® certification mark.

Characteristics: Interior fuel gas piping systems, using corrugated stainless steel tubing, to be used in installation in residential or commercial buildings. Components include tubing, fittings, manifolds and striker plates. May be used in conjunction with other approved fuel gas piping materials. May be used for fuel gas at maximum actual operating pressure not exceeding 5 psig. To be installed in accordance with the


Chairman, Product Certification Committee


CEO, The IAPMO Group



This listing period is based upon the last date of the month indicated on the Effective Date and Void After Date shown above. Any change in material, manufacturing process, marking or design without having first obtained the approval of the Product Certification Committee, or any evidence of non-compliance with applicable codes and standards or of inferior workmanship, may be deemed sufficient cause for revocation of this listing. Production of or reference to this form for advertising purposes may be made only by specific written permission of IAPMO Research and Testing, Inc. Any alteration of this certificate could be grounds for revocation of the listing. This document shall be reproduced in its entirety.